

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009346
DATE: 02/11/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Maxim
CODE: M-1256-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Maxim Industries, Inc. 1630 Terre Colony Court Dallas, TX 75212	Series "Maxim Impact Glass Curb Mount Skylight" Configuration: O Glazing: IG-1/8" Tempered Glass/Laminate- 1/8" Annealed Glass/0.090"Sentry Glass® Plus/1/8" Annealed Glass Overall: W-60.625" Daylight Size: W-58.375" H-61.25" H-56.375"

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94 ASTM E283/330/331 ASTM E1886-02/E1996-02	Design Pressure: +55.3/-55.3 psf Large Missile Impact Rated Wind Zone 4-Missile Level D

Product Tested By: Hurricane Test Laboratory, LLC.

Report No: T482-0604-07

Expiration Date: August 31, 2011

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "M. J. ...", written over a horizontal line.

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659