

## SECTION 08620—UNIT SKYLIGHTS

### Dade County/FBC/TDI Approved Impact Glass Skylight (Model(s) DGCM/DGSF)

#### PART 1: General

##### 1.01 Section Includes:

###### A. Scope:

This section includes everything necessary for and incidental to the execution and completion of the Florida Building Code, Dade County and Texas Department of Insurance approved Impact Glass glazed Curb Mount skylight as shown on all drawings and specified herein.

###### B. Work Included:

Work included, and is limited to, the skylight materials only and includes the following:

1. 1" Impact Glass with DuPont Sentry Glass Plus unit skylights complete with curb mount frame for installation on flashed curb by others or unfinished 2 X 6 SYP curb provided by Maxim Industries, Inc.

###### C. Related Work:

1. Division 7: Thermal & Moisture Protection.
2. Division 8: Windows & Doors.
3. Section \_\_\_\_\_ final cleaning.

##### 1.02 References and Approvals:

Architectural Testing, Inc., 130 Derry Court, York, PA 17402

**REPORT#: 01—43381.01**

Miami-Dade County Building Code Compliance Office

**Product Control Notice of Acceptance (NOA): 08-0219.02 Expires –May 15, 2013**

Sheffield Plastics, Inc., 119 Salisbury Road, Sheffield, MA 01257

**Product Control Notice of Acceptance (NOA): 01-0709.07 Expires: 08/27/2012**

Florida Building Commission 2555 Shumard Oak Blvd., Tallahassee, FL 32399-2100

**2004 Version of the Florida Building Code: Product Approval Number: FL #2418-R1**

Texas Department of Insurance 333 Guadalupe Austin, TX 78714-9104

**Texas Department of Insurance Evaluation Report no. SK-13**

Hurricane Test Lab, 525 32<sup>nd</sup> Street Lubbock, Texas 79404

**REPORT#: T482-0604-07**

Miami-Dade County Building Code Compliance Office

**Product Control Notice of Acceptance (NOA): 07-1105.05 Expires –Jan 10, 2013**

E.I. DuPont de Nemours & Co., Inc. 8480 DuPont Road Washington, WV 26181

**Product Control Notice of Acceptance (NOA): 06-1205.10**

National Accreditation & Management Institute 11870 Merchants Walk Newport News VA 23606

**Product, Manufacturing and Quality Assurance Certification No.: NI009346**

Construction Consulting Lab 1601 Luna Road Carrollton, Texas 75006

**AAMA/WDMA/CSA 101/I.S.2/A440-05 including: ASTM E283, ASTM E330, ASTM E331  
ASTM E547—Standard specification for windows, doors & skylights**

##### 1.03 Performance Criteria:

- A. Impact Resistance:  
Impact Glass glazed unit skylights must meet the requirements of Protocol TAS—201-94
- B. Static Air Pressure:  
Impact Glass glazed unit skylights must meet the requirements of Protocol TAS—202-94
- C. Cyclic Wind Pressure Loading:  
Impact Glass glazed unit skylights must meet the requirements of Protocol TAS—203-94
- D. Structural Loads:  
Impact Glass glazed unit skylights must meet the requirements of Protocol TAS—202-94; Design Load = +60.0 psf. & -100.0 psf.
- E. Cyclic Wind Pressure Loading:  
Impact Glass glazed unit skylights must meet the requirements of Protocol TAS—203-94; Design Load = +60.0 psf. & -100.0 psf.
- F. Other standards met or exceeded and thusly included in this specification:  
ASTM E330, ASTM E331, ASTM E283, ASTM E547, ASTM E1886, ASTM E1996

#### 1.04 Submittals:

- A. Shop Drawings:  
Submit \_\_\_\_\_ copies of manufacturers standard approval sheet for architects review and approval.

#### 1.05 Warranty:

Skylight manufacturer shall provide a written warranty against defects in materials and workmanship for a period of five (5) years from date of installation for frame and finish, seven (10) years for glazing.

#### 1.06 Manufacturer:

Dade Glass Curb Mount/ Dade Glass Self Flashing skylight(s) shall be Maxim Industries, Inc. model DGCM/ DGSF as manufactured by Maxim Industries, Inc., 1630 Terre Colony Court Dallas, Texas, 214-905-2021 with sizes as shown on drawings.

### **Part 2: Products:**

#### 2.01 Materials:

- A. Frame:  
Frame shall be fabricated from 6063-T5/T6 aluminum extrusion with a thickness of .090 or typical wall per extrusion blueprint. Frame shall include a condensation gutter applied to the interior side of the glazing made from 6063-T5/T6 aluminum extrusion with a thickness of .090 or typical wall per extrusion blueprint. All corners shall be welded using the heliarc process.
- B. DuPont Sentry Glass® Plus Impact Glass:  
DuPont Sentry Glass® Plus Impact Glass shall be secured to frame per product approval drawings.
- C. Aluminum Finish:

All exposed aluminum to be Mill Finish, Clear Anodized, Bronze Anodized, or Powder Coated Custom Color, as selected by architect.

D. Sealants:

1. Dow Corning 795 sealant:

Dow Corning 795 structural sealant applied continuously around perimeter of the skylight frame between the Glass and frame.

E. Fasteners:

No fasteners are supplied but must conform to product control approval drawings. Pre-positioned fastener holes are provided.

F. Curb:

Optional Curb provided by Maxim. Verify wood, aluminum (per 2.01 A) or other material as specified.

2.02 Assembly:

All skylights shall be factory assembled and factory glazed.

**Part 3 Installation:**

3.01 Site Inspection:

Installer shall notify general contractor/project manager of any structural or dimensional deficiencies immediately. No work shall proceed without the correction of all deficiencies or written authorization is given to proceed.

3.02 Installation:

Skylight shall be installed in strict accordance with installation drawings and instructions provided by the manufacturer. Any deviation shall only be through written authorization from the architect.

A. Sealants:

No sealants shall be applied to aluminum if temperature is below 32 degrees F.

3.03 Protection:

Protection of skylights during construction shall be the responsibility of the general contractor/project manager.

3.04 Cleaning:

A. General Cleaning:

Installer shall remove all protective coverings from frames and/or domes and shall leave installation free from heavy debris and/or sealant markings.

B. Final Cleaning:

Final cleaning in accordance with manufacturers recommendations shall be by the general contractor/project manager. Cleaning instructions shall be located on manufacturers label.

**End of Section**