NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI009346.01
DATE: 05/01/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Maxim
CODE: M-1256-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
MaximIndustries, Inc. **1630 Terre Colony Court** **Dallas, TX 75212**	**Series "Maxim Impact Glass Curb Mount Skylight"** Configuration: O Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Sentry Glass® Plus/1/8" Annealed Glass Overall: W-60.625" Daylight Size: W-58.375" H-61.25" H-56.375"

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94 **ASTM E283/E330/E331** **ASTM E1886-02/E1996-02**	**Design Pressure: +60/-100 psf** **Large Missile Impact Rated** **Wind Zone 4-Missile Level D**

Product Tested By: Hurricane Test Laboratory, LLC.
Report No: T482-0604-07
Expiration Date: **August 31, 2017**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122