

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013491.01
DATE: 01/31/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Maxim
CODE: 1256-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Maxim Industries, Inc. 1630 Terre Colony Court Dallas, TX 75212	Series "BCM" Aluminum Skylight Configuration: O Glazing: Double Glazed w/Exterior Dome- 5Layer Multi-Wall 0.118" Polycarbonate (Ext) Frame: W-1842mm(72.5") H-1842mm(72.5") DLO: W-1734mm(68.25") H-1734mm(68.25")

SPECIFICATION	PRODUCT RATING
ASTM F1642-2012 ASTM F2912-2011 GSA-TS01-2003	Average Peak Reflected Pressure: 6.97 psi Average Positive Phase Impulse: 40 psi-msec Average Positive Phase Duration: 11.45 msec ASTM Hazard Rating: No Hazard ASTM System Rating: H1 GSA Performance Condition: 2 UFC Level of Protection: Medium

Product Tested By: Architectural Testing, Inc.
Report No: F5594.01-119-12
Expiration Date: **January 31, 2021**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122