



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208

Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Maxim Industries, Inc.
1630 Terre Colony Court
Dallas, Texas 75212

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Model BCM Curb Mount Skylight

APPROVAL DOCUMENT: Drawing No. 18-6912, titled "Model BCM Dade Curb Mount Skylight", prepared by Engineering Express, dated September 28, 2018, sheet 1 and 2 of 2, signed and sealed by Frank L. Bennardo, P.E., on November 12, 2018 bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and the expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved or MDCPCA", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA #17-0411.02 and consists of this page 1, evidence submitted page E-1 as well as approval document mentioned above.

The submitted documentation was reviewed by **Helmy A. Makar, P.E., M.S.**



Helmy A. Makar
01/24/2019

NOA No. 18-1120.08
Expiration Date: 08/03/2022
Approval Date: 01/24/2019

Maxim Industries, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL #17-0411.02

A. DRAWINGS

1. *Drawing No. MS0217, titled "Model BMC Dade Curb Mount Skylight", prepared by Maxim Industries, Inc., dated 02/10/17, sheet 1 and 2 of 2, signed & sealed by Theodore Berman, P.E.*

B. TESTS

1. *Test reports on 1) Air Infiltration Test, per FBC, TAS 202-94; 2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94; 3) Water Resistance Test, per FBC, TAS 202-94; 4) Large Missile Impact Test per FBC, TAS 201-94; 5) Cyclic Wind Pressure Loading per FBC, TAS 203-94 along with marked-up drawings and installation diagram of Model BCM, prepared by Intertek / Architectural Testing, Test Report No. G5934.01-801-18, dated 01/03/17, signed and sealed by Tyler Westerling, P.E.*

C. CALCULATIONS

1. *Anchor calculations, 7 sheets, issued by Ted Berman and Associates, LLC, dated March 30, 2017, signed and sealed by Theodore Berman, P.E.*

D. QUALITY ASSURANCE

1. *Miami Dade County Department of Regulatory and Economic Resources (RER).*

E. MATERIAL CERTIFICATION

1. *None.*

F. STATEMENTS

1. *FBC, 2014 Edition, Compliance Letter issued by Ted Berman and Associates, LLC, dated 03/30/17, signed & sealed by Theodore Berman, P.E.*

2. NEW EVIDENCE SUBMITTED

A. DRAWINGS

1. *DWG. #18-6912, titled "Model BCM Dade Curb Mount Skylight", prepared by Engineering Express, dated 09/28/18, 2 sheets, signed & sealed by Frank L. Bennardo, P.E., on 11/12/18.*

B. TESTS

1. *None.*

C. CALCULATIONS

1. *None.*

D. QUALITY ASSURANCE


1. *Miami Dade County Department of Regulatory and Economic Resources (RER).*

E. MATERIAL CERTIFICATION

1. *None.*

F. STATEMENTS

1. *FBC, 2017 Edition, Compliance Letter issued by Engineering Express, dated 11/12/18, signed & sealed by Frank L. Bennardo, P.E.*




Helmy A. Makar, P.E., M.S.
Product Control Section Supervisor
NOA No. 18-1120.08
Expiration Date: 08/03/2022
Approval Date: 01/24/2019



DRWN	CHKD	DATE
LEA	ALP	08/28/18
REMARKS		
THIS DOCUMENT IS THE PROPERTY OF ENGINEERING EXPRESS. IT IS NOT TO BE REPRODUCED IN WHOLE OR PART WITHOUT THE WRITTEN CONSENT OF ENGINEERING EXPRESS. ALL RIGHTS RESERVED AND INVAOLVING OUR CERTIFICATION.		
COPYRIGHT ENGINEERING EXPRESS®		

Design Pressure = +60psf/ -60psf
(test pressure = +180psf/ -120psf)

Model BCM



- Notes:
- This skylight is designed to comply with all requirements of the 6th edition of the Florida Building Code (2017).
 - This skylight is designed to comply with all wind zones, including the HVHZ, of the 6th edition of the Florida Building Code (2017).
 - This skylight meets small & large missile impact resistance (TAS-201/ASTM E1886/ASTM E1996) and no other protection is required.
 - This skylight complies with TAS 201, 202, 203
 - This skylights complies with AAMA/WDMA/CSA 101/1.S.2/A440 and AAMA 101
 - All sizes equal to or less than the test size total square footage are to be accepted under this product approval; NOA, FBC#, TDI Report, UFC 4-010-01, and GSA-TS01-2003.
 - All framing, roof deck, flashing, and fasteners are by others and must comply with the 6th edition of the Florida Building Code (2017).
 - Fasteners used to attach skylight to wood curb are to be minimum #12 stainless steel with minimum embedment of 1.25".


Bill of Materials:

- 6063-T5 Extruded Aluminum Frame mitered and welded at four corners.
- 6063-T5 Extruded Aluminum Angle, 2" X 2", mitered and welded at four corners.
- Covestro SL or PalRam UV Enhanced .118" Polycarbonate dome.
- Gallina PolCarb 5 Layer, 16mm RDC Multiwall Polycarbonate.
- Dow Corning 795 Silicone Building Sealant located between aluminum angle and outer dome.
- ITW SM 5127 Sealant Tape located between 16mm RDC multiwall and extruded aluminum frame.
- #10 X .375" Stainless steel fasteners 4" from each corner, maximum 6" on center.
- #12 X 1.5" Stainless steel fasteners 4" from each corner, maximum 6" on center with minimum embedment of 1.25".

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 18-112e-08
Expiration Date 08/03/2022

By: *Heidi A. Miller*
March Design Product Control

11/12/2018



ENGINEERING EXPRESS
CORPORATE OFFICE
160 SW 12th Ave, Suite 106
DERRFIELD BEACH, FL 33442
P: (954) 354-0660 F: (954) 354-0443
E: HELLO@ENGINEERINGEXPRESS.COM
CENT OF AUTH # 9885


MAXIM INDUSTRIES, INC.
1630 TREE COLONY COURT
DALLAS, TX 75212
DADE CURB MOUNT SKYLIGHT

DATE	CHD	DRWN	REMARKS
02/28/18		AJP	INIT ISSUE


THIS DOCUMENT IS THE PROPERTY OF ENGINEERING EXPRESS. IT IS NOT TO BE REPRODUCED IN WHOLE OR PART WITHOUT WRITTEN CONSENT OF ENGINEERING EXPRESS. ALL RIGHTS RESERVED AND INVALIDATE OUR CERTIFICATION.

SCALE(S) UNLESS NOTED
18-6912
OF 2

**Detail #1:
Frame, Angle & Glazing Section Detail**




**Detail #4
Aluminum Angle Weld Detail
AFCO Part #AF-4230
2" X 2"**



PRODUCT REVISED as complying with the Florida Building Code
Acceptance No. 18-1120-08
Expiration Date 08/03/2022
By: *Heather A. Miller*
Miami Design District Control

**Detail #3
Aluminum Shape Weld Detail
AFCO Part #AF-4950**



Detail #2: Glazing Detail

